

Instrumental Research, Inc. 7800 Main Street NE Fridley, MN 55432. Ph. 763-571-3698 Fax. 763-571-3372

Monday, November 13, 2023 LABORATORY ANALYSIS REPORT 1415-23 MDH CERTIFIED LABORATORY 027-003-130 EPA LAB CODE MN 00076

Attn: Arif Bakar	
Bultum Academy	Date Collected: 11/3/2023
1555 40th Ave NE	Date Received: 11/3/2023
Columbia Heights, MN	Collected By: Client

Parameter/Method	Sample ID	Results	Units	MDL	Reporting Limit	Analysis Date
	Bultum 1555 40th Ave NE					11/3/2023
Lead** SM 3113 B-99	Water Fountain (1415-23-01)	<2.5	ug/L		2.5	11/13/2023

** Subcontracted to Water Labs file #84646 *MDL* = *Method detection level Temp Blank* >4.0 *degrees C* Sample was collected on 11/3/23 at 9:51, received at IRI on 11/3/23 at 11:03. Sample DOES MEET MDH and EPA primary drinking water requirements for safe drinking water. The results are only indicative for the sample tested from the sample point on the date collected.

All analyses were performed using Minnesota Department of Health approved methodologies.

Report submitted by,

Despron M. Kelchik

SUZANNE MELCHIOR, LABORATORY MANAGER SM/kg

The results in this report apply only to the samples analyzed in accordance with the chain of custody document. This report must be reproduced in its entirety.